

SQAD-6 Quality Control Notice (QCN)

Sub Code: LEAK

Seat Leakage test report

Each item or material ordered for which this quality statement is specified requires a "Certification of Seat Leak Test." This certification shall indicate the hydrostatic test pressure duration and amount of leakage per unit time. The certification (which may be included in "Certification of Hydrostatic Testing") shall include the test results. Seat leak testing procedures and acceptance criteria shall conform to the requirements of the Code as specified in the Exelon PO/Contract or its references. Upon completion of testing, item should be verified dry and packaged to prevent the entrance of moisture.