

SQAD-6 Quality Control Notice (QCN)

Sub Code: EDDY

Eddy Current test

Each item for which this quality statement is specified requires the submittal of an Eddy Current Examination. Examination procedures and reporting shall conform to the requirements of the ASME B&PV Section V, Article 8 and mandatory addenda as specified in the Exelon PO/Contract. Certification shall include the examination procedure, revision and examination results.